



**SECTION**  
NOT TO SCALE

NOTES:

1. 8" PRV STATION SHOWN. 6" PRV STATION IS IDENTICAL EXCEPT THE UPSTREAM AND DOWNSTREAM PIPING, FITTINGS, AND VALVES ARE 6".
2. PAINT ALL EXPOSED PIPING AND FITTINGS WITHIN VAULT AND ABOVE GRADE.
3. ALL VALVES INSIDE VAULT TO HAVE HAND WHEEL OPERATORS.

APPROVED: SCOTT THOMASSON  
REV. DATE: FEB. 1, 1997

WATER/WASTEWATER DIVISION



STANDARD DETAILS

**6" AND 8" PRV STATION  
SECTION**

FILE SD709B.DWG DRAWING NO. **709B**